
Water Plant

The water treatment plant has been running smoothly. In June, the plant was operational for **30** days with an average plant production of **2.2** MGD and a max day of **3.5** MGD.

Construction on the Emergency Overflow Pond project has begun. GESC measures have been set-up and approved by Douglas County, removals of the old backwash influent line and decant structure has been completed and the site is ready for the earthwork.

GESC permits for the Old Water Treatment Plant Demolition Site and New Water Plant Site have been closed out by Douglas County.

June production was **65.4** million gallons of treated water, **19.8** million gallons of that was for Sterling Ranch.

Lift Stations

The lift stations are running smoothly.

June saw **24** million gallons of sewage pumped to Littleton-Englewood. Approximately **3.3** million was conveyed for Sterling Ranch.

Field

The field remains busy for June with over **645** locates, most of them were in Sterling Ranch, **190** were in Roxborough.

Brannan continues to install sewer mainline on Rock Wren; progress remains slow as there is bed rock towards the bottom of the trench that is having to be jackhammered out.

Summer helpers continue to keep up on grounds maintenance at the facilities, fire hydrant maintenance in the distribution system and general upkeep at the facilities.

Monthly Averages

